



Frankfort Plant Board

BID INVITATION #1748

ISSUED ON

April 28, 2022

BY

**THE ELECTRIC & WATER PLANT BOARD OF THE
CITY OF FRANKFORT, KENTUCKY**

FOR

Underground Cable

TO BE OPENED ON

May 10, 2022 at 1:30PM

II. TABLE OF CONTENTS**Underground Cable**

	<u>PAGE</u>
I. TITLE PAGE	1
II. TABLE OF CONTENTS	2
III. ADVERTISEMENT FOR BID	3
IV. INTRODUCTION	4
V. INSTRUCTIONS	5-7
VI. SPECIFICATIONS	8-11
VII. BID PRICING FORM	12
VIII. SIGNATURE PAGE	13
IX. EEOC CERTIFICATE (IF INCLUDED)	14-15
X. GENERAL SAFETY PROGRAM	16-17
XI. DRUGFREE WORKPLACE COMPLIANCE CERTIFICATE	18

III. ADVERTISEMENT FOR BID

**The Frankfort Plant Board
305 Hickory Drive
Frankfort, KY 40601**

Separate sealed Bids for underground cable will be received by the Frankfort Plant Board until May 10, 2022 @ 1:30PM; and then opened and publicly read aloud.

Specifications may be examined at the following location:

Frankfort Plant Board
Service Center
305 Hickory Drive
Frankfort, KY 40601

No bidder may withdraw his bid for a period of ninety (90) days after closing time scheduled for the receipt of Bids.

The Plant Board reserves the right to waive informalities and to accept or to reject any and all bids.

For Bid Correspondence, contact:

**Jennifer Hellard
(502) 352-4422
jhellard@fewpb.com**

For Technical Correspondence, contact:

**Jim Carter
(502) 352-4401
jcarter@fewpb.com**

IV. INTRODUCTION

Underground Cable

The Electric & Water Plant Board of the City of Frankfort, Kentucky issues this Invitation to solicit bids on the purchase of underground cable.

Quoted prices shall be firm F.O.B. with freight included to Frankfort, Kentucky.

Material included on this bid is item specific. No exceptions shall be made.

Please note instructions on Pages 5-7. Failure to adhere to instructions may result in rejection of bid.

**READ CAREFULLY -- BIDDER MUST PROVIDE ALL INFORMATION REQUESTED --
SIGN BID**

If an EEOC Certificate is included as a part of this documentation, it shall be executed and returned as a part of the bid response package. Absence of the EEOC Certificate indicates your organization already has the necessary compliance certificate on file with the Plant Board.

V. INSTRUCTIONS TO BIDDERS**1. SUBMISSION OF BIDS**

A. The following certificates or notices are included as a part of this documentation and shall be returned as a part of the bid response package.

- An Equal Employment Opportunity Compliance (EEOC) Certificate
- A Certification of Nonsegregated Facilities (CONF)
- A General Safety Program (GSP) Notice
- A Drug free Workplace Compliance (DWC)

B. Each bid should be in a SEPARATE SEALED ENVELOPE and have typed on the envelope the INVITATION NUMBER, OPENING DATE, AND TIME. No responsibility will be attached to the Frankfort Electric & Water Plant Board for the premature opening of or failure to open a bid not properly addressed or identified. Bids must be received in the office of the Frankfort Electric & Water Plant Board, 305 Hickory Drive, P. O. Box 308, Frankfort, Kentucky, 40602, in a sealed envelope not later than the time specified for opening of bids, at which time all bids received will be publicly opened and read in the Bid Opening Room. It shall be the Bidder's responsibility that the bids are delivered to the above address no later than the time specified. Bidders are invited to attend public bid openings; also, to review complete bid files after awards have been made.

C. Bids may be rejected unless filled out in ink or typewritten and signed in ink by a proper agent of the firm.

D. Telegraphic bids, facsimile bids, or modifications of bids by telegram are not acceptable.

E. Conditional bids are not acceptable.

F. It is the responsibility of each Bidder before submitting a Bid to:

- Examine the Bid and Contract documents thoroughly.
- Consider federal, state, and local laws and regulations that may affect cost, progress, performance, or furnishing of the work.
- Study and carefully correlate Bidder's observations with the Bidding and Contract documents and notify Owner of all conflicts, errors, and/or the discrepancies.

G. All bids shall remain subject to acceptance for a period of ninety (90) days after the date of the Bid opening.

H. Retain one complete copy of the bid for your file and return original with your bid.

- I. Bids may be withdrawn at any time prior to opening upon written request by the bidder. Negligence on the part of the bidder in preparing his bid shall not constitute a right to withdraw bid after it has been opened.
- J. Bidders are invited to attend public bid opening; also, to review complete bid files after awards have been made.

2. BID SCHEDULE/SIGNATURE PAGE

- A. Bidders should quote on the basis of units stated in this invitation. Unit price should be entered and EXTENDED. In case of error in the extension of prices, the unit price will govern. For discrepancies between figures and written amounts, precedence will be given to the written amounts.
- B. Bids by corporations must be executed in the corporate name by the president or a vice-president (or other corporate officer accompanied by evidence of authority to sign) and the corporate seal must be affixed and attested by the secretary or an assistant secretary. The corporate address and state of incorporation must be shown below the signature.
- C. Bids by partnerships must be executed in the partnership name and signed by a partner, whose title must appear under the signature and the official address of the partnership must be shown below the signature.
- D. All names must be typed or printed below the signature.
- E. The Bid shall contain an acknowledgement of receipt of all Addenda (the numbers of which must be filled in on the Bid Form).
- F. The address, telephone number and contact person for communications regarding the Bid must be shown.

3. QUALIFICATIONS OF BIDDERS

To demonstrate qualifications to perform work, each Bidder must be prepared to submit within five (5) days of Owner's request, written evidence such as financial data, previous experience, present commitments and other such data as may be called for. The Owner may make an investigation as deemed necessary to determine the ability of the Bidder to perform the work, and the Bidder shall furnish to the Owner all such information and data for this purpose, as the Owner may request. The Owner reserves the right to reject any bid if the evidence submitted by, or investigation of, such Bidder fails to satisfy the Owner that such Bidder is properly qualified to carry out the obligations of the Contract and to complete the work contemplated therein.

4. AWARD OF CONTRACT

A. The Owner reserves the right to reject any and all Bids and to waive informalities or minor defects. Any Bid may be withdrawn prior to the above scheduled time for the opening of Bids or authorized postponement thereof. Any Bid received after the time and date specified shall not be considered. No Bidder may withdraw a bid within 90 days after the actual date of opening thereof. Should there be reasons why the contract cannot be awarded within the specified period, the time may be extended by mutual agreement between the Owner and the Bidder. In the event that the lowest responsive and responsible bid is within the Owner's budget, the Contract will be awarded to the lowest responsive and responsible Bidder which, in the Owners sole and absolute judgment, will best serve the interest of the Owner

B. In determining the best responsive and responsible Bidder, the following elements will be considered: (1) lowest price, (2) if the Bidder has a satisfactory performance record, (3) if the Bidder has a suitable financial status to meet obligations incidental to the work, (4) if the Bidder involved maintains a permanent place of business, (5) if the Bidder has adequate personnel and equipment to perform the work properly within the time allotted, (6) number of and acceptability by the Owner of any and all proposed Subcontractors, (7) the completeness and regularity of the Bid Schedule and (8) time schedule of delivery. In addition, the Owner may consider in making the determination (1) quality of equipment (or materials), (2) efficiency and environmental aspects of equipment (or materials) (3) the selection of equipment (or materials), (4) alternate equipment (or materials), and (5) deductions or other modifications listed in the Bid Schedule.

5. LAWS AND REGULATIONS

The Bidder's attention is directed to the fact that all applicable State Laws, municipal ordinance, and the rules and regulations of all authorities having jurisdiction over construction of the Project shall apply to the Contract throughout, and they will be deemed to be included in the Contract the same as though herein written out in full.

VI. SPECIFICATIONS

Underground Cable

This specification covers single conductor underground distribution cable having a concentric neutral suitable for installation in underground ducts, conduit, and, direct burial, for use in wet and dry locations, for conductor size **1/0 & 4/0** AWG. Insulation shall be EPR.

GENERAL CONDITIONS

The cable shall be rated 90 degrees C for normal operation, 130 degrees C for emergency overload operation and 250 degrees C for short circuit conditions. Emergency overload operation may occur for periods up to 72 hours per year and with as many as three such 72-hour periods within any consecutive 12-month period.

Cable will be used on a 13.2 KV, three-phase, 60 Hz, multi-grounded wye distribution system.

Cable shall meet or exceed the applicable sections of the latest editions of the following industry standards:

- ICEA - Insulated Cable Engineers Association
- AEIC - Association of Edison Illuminating Companies
- ASTM - American Society for Testing and Materials
- NEMA - National Electrical Manufacturers Association
- IEEE - Institute of Electrical and Electronics Engineers

PARAMETERS:

Conductor Size 1/0 & 4/0

Conductor Material Aluminum

Insulation EPR

Insulation Thickness 220 mil

Jacket Black Linear Low Density Polyethylene

CONDUCTOR

1. Uncoated aluminum alloy 1350 wire, class B, strand-compressed concentric - lay round.

Aluminum per ASTM B-230/231

2. The center strand shall be stamped showing the following:

- A. Manufacturer
- B. Year of manufacture

CONCENTRIC NEUTRAL

- 1. Provide a full copper concentric neutral on 1/0 size conductors
- 2. Provide a 1/3 copper concentric neutral on 4/0 size conductors

CONDUCTOR SCREEN

1. A stress control screen of semiconducting thermosetting or insulating black material shall be extruded concentrically over the conductor strand. Minimum average thickness of the conductor screen measured over the top of the conductor strands shall be 15 mils for insulating materials and 25 mils for semiconducting materials. Screens shall conform to applicable AEIC Standards.

2. The conductor screen shall be easily removable from the conductor in the field with conventional stripping tools.

INSULATION

EPR – Ethylene-Propylene thermosetting Rubber

- 1. The primary insulation wall shall be concentrically extruded over the conductor screen and shall be chemically and structurally compatible with the conductor screen.
- 2. The red orange color of the insulating compound shall be in contrast to the color of the conductor screen.
- 3. The primary insulation shall be tested for voids and contaminants using the requirements of AEIC CS6-1982, Section A.3.

INSULATION SCREEN

1. A stress control screen of the same material as the conductor screen as previously specified to be extruded concentrically over the insulation.

2. The extruded screen shall be clean stripping and shall have a peel strength from the insulation between 6 and 18 LB/0.5 inch width when tested per AEIC.
3. Minimum average thickness of the insulation screen shall be 35 mils for insulating materials and 50 mils for semiconducting materials.

SHIELDING SYSTEM

1. A layer of equally spaced solid bare copper wires shall be applied helically over the semiconducting insulating screen.
2. Copper wires for a full concentric neutral shall be:
 Conductor size 1/0 16 # 14 wires
3. Copper wire for a one-third concentric neutral shall be:
 Conductor size 4/0 11 # 14 wires

ENCAPSULATING JACKET

1. The jacket shall be of black linear low density, high molecular weight polyethylene extruded over the concentric neutral.
2. The jacket shall substantially fill the spaces between the concentric neutral wires and shall be free stripping from the insulation screen and concentric neutral.
3. The outer surface of the encapsulating jacket shall have three (3) integrated red identification stripes spaced 120° apart. The stripes shall be approximately 0.25" wide.
4. The following identification legend shall be indent printed on the overall jacket and repeated at two-foot intervals:
 - a. Manufacturer
 - b. Year of manufacture
 - c. Insulation thickness
 - d. Voltage rating
 - e. Conductor material and size
 - f. Sequential footage numbers in a white ink

INSPECTION AND TESTING

The tests specified below shall be performed on the entire length of cable delivered. The cable shall be subjected to and shall pass the following tests in accordance with the applicable recognized standards:

1. Electrical resistance tests of conductors shall be performed in accordance with ICEA.
2. Insulation resistance tests shall be performed in accordance with the requirements of ICEA. Test data shall indicate the insulation resistance constant, K, used in the calculation of insulation resistance, corrected to 15.6 degrees C (60 degrees F).

3. High voltage AC and DC withstand tests shall be performed in accordance with ICEA. Voltages applied shall be 33 KV, 60 Hz AC for 5 minutes, and 80 KV DC for 15 minutes.
4. Electrical resistance tests of shields shall be performed to verify continuity.
5. Corona tests shall be performed on each shipping reel of completed cable in accordance with AEIC.
6. Two copies of complete and bound test reports certified by the Manufacturer shall be provided to the Engineering Department for review prior to shipment. Mail to the following address:

James R. Carter, P.E.
Frankfort Electric and Water Plant Board
P. O. Box 308
Frankfort, Kentucky 40602

PACKAGING, MARKING, AND SHIPPING

1. Cable shall be shipped on non-returnable wood reels with 2500' of cable per reel.
2. Cable ends shall be sealed with a watertight cap or seal. Cable ends shall be securely fastened to the reel using polypropylene rope ties. Metal ties or staples will not be acceptable.
3. Each reel of cable shall have a weatherproof tag attached to its outer end, and the exterior of the reel shall have a similar weatherproof marking showing cable description, actual length, net weight, gross weight of cable, and reel as shipped, Purchase order number, destination, and any other data for identification as may be required.

VII. BID PRICING FORM

Underground Cable

ITEM #	QUANTITY	DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	15,000 ft. (6 reels of 2500' each)	Cable, #1/0 URD Primary Jacketed Neutral Manufacturer: _____		
2	15,000 ft. (6 reels of 2500' each)	Cable, #4/0 URD Primary Jacketed Neutral Manufacturer: _____		
		GRAND TOTAL		

VIII. SIGNATURE PAGE

UNDERGROUND CABLE

We submit the prices on page 12 and agree to make delivery within _____ days after receipt of order.

This offer shall be valid for 90 calendar days from the date this bid is opened.

GRAND TOTAL WRITTEN IN WORDS: _____

SIGNED BY: _____

PRINTED NAME: _____

EMAIL: _____

FIRM: _____

ADDRESS: _____

TELEPHONE NUMBER: () _____

E-MAIL ADDRESS: _____

FAX NUMBER: () _____

DATE: _____

IX. EQUAL EMPLOYMENT OPPORTUNITY COMPLIANCE CERTIFICATE

A. Has your company filed the required Employer Information Report, EEO-1 (Standard Form 100) with the Secretary of Labor's Joint Reporting Committee for the prior period ending March 31?

YES

NO

If your answer to Question A above is "NO", check the following appropriate reasons for not filing:

1. Employ less than one hundred people company-wide.
2. Have specific exemption from Secretary of Labor as provided in Section 20 of Executive Order 11246, as amended.

Within Thirty (30) days after receipt of any order from the **Frankfort Electric and Water Plant Board** and prior to each March 31 thereafter, during the performance of work under said order, the undersigned firm agrees to file Standard Form 100, entitled "Equal Employment Opportunity Information Report EEO-1" in accordance with instructions contained therein, unless such firm has either filed such report within twelve months preceding the date of the award or is not otherwise required by law or regulations to file such a report.

B. In consideration of the undersigned being placed in the **Frankfort Electric and Water Plant Board's** "Supplier Document" for the year ending March 31 next, the undersigned certifies that he does not and will not maintain or provide for his employees any segregated facilities at any of his establishments and that he does not and will not permit his employees to perform their services at any location under his control where segregated facilities are maintained. The undersigned agrees that a breach of this certification is a violation of the Equal Opportunity Clause in any subcontract, contract, purchase order, or agreement that the undersigned may receive from the **Frankfort Electric and Water Plant Board**.

As used in this certification, the term "Segregated facilities" means any waiting room, work areas, rest room, and washrooms, restaurants and other eating areas, time clocks, locker rooms, and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation, and housing facilities provided for employees which are segregated on the basis of race, creed, color or national origin, because of habit, local custom or otherwise.

The undersigned further agrees that he will obtain identical certifications from proposed subcontractors prior to the award of subcontracts exceeding \$10,000 which are not exempt from the provisions of the Equal Opportunity Clause; that he will retain such certification in his files and that he will forward the following notice to his proposed subcontractors (except when the proposed subcontractors have submitted identical certification for specific time periods).

"NOTICE TO PROSPECTIVE SUBCONTRACTORS OF REQUIREMENT FOR CERTIFICATION OF NONSEGREGATED FACILITIES"

"A certification of Nonsegregated Facilities, as required by the May 9, 1967 order on Elimination of Segregated Facilities, by the Secretary of Labor (32 Fed. Reg. 7439, May 19, 1967) must be submitted prior to the award of a subcontract exceeding \$10,000 which is not exempt from the provisions of the Equal Opportunity clause. The certification for all subcontractors during a period (i.e., quarterly, semi-annually, or annually).

(Note: The penalty for making false statements in offers is prescribed in 18 U.S.C. 1001.)"

C. Do you have at each of your facilities a current written Affirmative Action Compliance Program as required by Title 41 of the Code of Federal Regulations (CFR) 60-1.40; and current written Affirmative Action Programs for disabled veteran, veterans of the Vietnam Era and Handicapped workers as required by CFR 60-250.4 and CFR 60-741.4?

YES

NO

If "NO" within 120 days after receipt of any order resulting from attached quotation, the undersigned firm agrees to develop and maintain written Affirmative Action Compliance Programs as required. (Current law requires the contractor to develop a written Affirmative Action Compliance Programs in those cases where the contractor has received prime contract or subcontracts for \$50,000 or more and employs fifty (50) or more people).

CONTRACTOR (SELLER/SUPPLIER): _____

MAILING ADDRESS / PHONE: _____

Authorized Representative's
NAME (PRINT OR TYPE): _____

Authorized Representative TITLE: _____

Dated Signature of Authorized Representative: _____

X. "NOTICE TO PROSPECTIVE CONTRACTORS OF REQUIREMENT OF GENERAL SAFETY PROGRAM"

The Frankfort Plant Board requires that all contractors operate in compliance with standards set forth by federal, state, and local regulatory agencies, including but not limited to the Occupational Safety and Health Administration, Environmental Protection Agency and Department of Transportation. To comply with the regulations set forth by these agencies it is necessary for each contractor to operate under an established safety program pertaining to the contractor's specific line of business.

The primary goal of a safety program is to protect the health and safety of employees and the public. Our goals are also to conserve and protect property and the environment. **IT IS OUR ABSOLUTE CONVICTION THAT:**

- This is a moral responsibility of each firm and worker involved.
- Safe and healthful work is more efficient, effective and inseparable from how we perform our work.
- Accidents and injuries are unnecessary costs

We accomplish work which is free from accident and injury by providing vigorous leadership that is visible through the organization.

How well we conduct our work in a hazard-free manner, according to the direction provided, is a key factor in our performance for which we are each accountable.

There are certain basic elements that are incorporated into the safety program:

- Effective management leadership from each contractor;
- Organization of a **General Safety Program**;
- On-site supervisor with authority to carry out their responsibilities including suspension of work to correct unsafe conditions;
- Proper training and supervision; and
- Employee participation

Does your organization operate under an established safety program that is in compliance with all applicable federal, state and local regulations and does this program embody the philosophies described above?

YES

NO

CONTRACTOR (SELLER/SUPPLIER): _____

MAILING ADDRESS / PHONE: _____

Authorized Representative's
NAME (PRINT OR TYPE): _____

Authorized Representative TITLE: _____

Dated Signature of Authorized Representative:

If you received this as part of an Invitation to Bid, please return with your bid.

OTHERWISE

Please return to: Safety Officer
Frankfort Electric and Water Plant Board
PO Box 308
Frankfort, KY 40602

*Frankfort Electric and Water Plant Board
PO Box 308, Frankfort KY 40602*

XI. DRUGFREE WORKPLACE COMPLIANCE CERTIFICATE

PLEASE SIGN BELOW TO INDICATE: 1) Contractor is in compliance with any applicable local, state or federal laws concerning mandatory Drug and Alcohol Testing Programs; and 2) AS a term of any contract, the Contractor agrees to comply with any such drug and/or alcohol testing that may be required by law.

CONTRACTOR : _____
MAILING ADDRESS/PHONE: _____

Authorized Representative's
NAME (Print or Type): _____
Authorized Representative's TITLE: _____
SIGNATURE & DATE: _____

**If you received this as part of an Invitation to Bid please Return with your BID;
Otherwise, Return to: Personnel/Safety Officers, PO Box 308, Frankfort KY 40602**

**DRUGFREE WORKPLACE COMPLIANCE
CERTIFICATE**